

## Certified Validation Report Template, Part B: Provided by Utility

Water Supplier Name: City of Gilroy

Water Supplier ID Number: 3610013

Water Audit Period: Calendar 2017

### Water Audit & Water Loss Improvement Steps:

*Steps taken in preceding year to increase data validity, reduce real loss and apparent loss*

- Metering of non-billed city water use
- Possible meter testing
- Annual calibration of all production meters

### Certification Statement by Utility Executive:

This water loss audit report meets the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34 and has been prepared in accordance with the method adopted by the American Water Works Association, as contained in their manual, *Water Audit and Loss Control Programs, Manual M36, Fourth Edition* and in the Free Water Audit Software version 5.

Utility Provided

Russ Handy

Executive Name (Print)

Utilities Superintendent

Executive Position

*Russell Handy*

Signature

12-20-18


Date



MC ENGINEERING

4400 River Road, Suite 500, Folsom, CA 95630

916-205-6510



## Wave 4 Water Audit Level 1 Validation Document

### Audit Information:

Water Supplier Name: City of Loma Linda PWS ID: 3610013

System Type: Potable Audit Period: Calendar 2017

Utility Representation: Russ Handy

Validation Date: 12/10/0218 Call Time: 1:00 p.m. Sufficient Supporting Documents Provided: Yes

### Validation Findings & Confirmation Statement:

#### Key Audit Metrics:

Data Validity Score: 72 Data Validity Band (level): Band III (72-100)

ILI: 7.69 Real Loss: 99.49 (gal/conn/day) Apparent Loss: 11.00 (gal/conn/day)

Non-revenue water as percent of cost of operating system: 8.7%

#### Certification Statement by Validator:

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. ☒

### Validator Information:

Water Audit Validator: Richard Relyea Qualifications: Water Audit Validator Certified by the CA-NV Section of the AWWA

Validator Provided

MC ENGINEERING

1000 River Rock Drive, Ste. 203, Folsom 916-205-6510